


STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM 'A'

1	Name of the school :	CRESENT SCHOOL (CBSE)
2	Location(Street no, Ward no, Name of place i.e, corporation/Municipality/ Panchayat Union/Township/ Cantonment) :	Seethakathi Estates, GST road, Vandalur, S.No. 289/3 & 289/4 Vandalur Taluk, Chengalpattu District
3	Year of Construction :	1993
4	Approximate Cost of Construction for the total area :	Rs.250 Lacs
5	Purpose for Which the Building is being is used or proposed to be used :	For Conducting School Classes
6	Purpose for Which the Building has hitherto been used :	For Conducting School Classes
7	Details of Construction of the building (Particulars of the foundation soil) :	RCC Framed structure (Isolated sloped murrum)
8	Plinth area of Floor :	12500 Sq.ft
9	No of floors :	GF+1
10	Specification for the various parts under:	
	(a) Foundation Footing:	RCC Column & Isolated foundation
	(b) Basement :	RCC Plinth beam & brick in CM 1:5
	(c) Superstructure:	RCC Plinth beam & brick in CM 1:5
	(d) Corridor width:	2.0m
	(e) Floor:	Cement
	(f) Lift:	1
	(g) Total No. of staircase:	4
	(h) Windows:	Alumminium Panel withGrill
	(i) Walls:	Brick Masonry CM 1:5
	(j) Doors:	Flush Doors
11	Period for which license is issued:	May be issued from 27.12.2023 to 26.12.2026 (For Three years only)
12	Area of the building:	25000 Sq. ft
13	Total height:	7.3 M
14	Number of person to be Accommodated:	500

Place: Chennai

Dated: Dec 2023

SIGNATURE OF THE OWNER OF THE BUILDING


Correspondent
CRESCENT SCHOOL
Vandalur, Chennai-600 045


PANEL AND STRUCTURAL ENGINEER


Dr.R.S.MURALITHARAN B.E.,M.E(Struct),Ph.D
Registered Structural Engineer Grade-1 (SE)
CMDA Reg. No. SE/GR-1/19/12/233
DTCP Reg. No. CGLRGTN/SE/Gr-1/2020/02/004
District Panel Engineer Class-1A
Structural Engineer Consultant
No: 7A/25, Muthusamy Street, Perungalathur, Chennai-63.
☎: 9489358800 ✉: rsmurali06@gmail.com

ANNEXURE TO "STATEMENT ACCOMPANYING FORM -A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched roof buildings are used for conducting any classes within the school premises. If any thatched buildings are constructed/used after the issue of this certificate, we would be held responsible for any fire accident/mishap that may occur later and that I am aware that the certificate will be cancelled.


Authorized signatory
Correspondent
CRESCENT SCHOOL
Vandalur, Chennai-600 048.

FORM - B


Form of Certificate of Structural Soundness under sub-section (B) of section 4 of the Tamil Nadu Public Building (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

I have inspected the building mentioned in the statement below and the building is to be used as a public building for the purpose noted in the statement WITH REMARKS.

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

1	Name of the School	CRESENT SCHOOL (CBSE)
	Location(Street no, Ward no, Name of place i.e, corporation/Municipality/ Panchayat Union/Township/ Cantonment)	Seethakathi Estates, GST road, Vandalur, S.No. 289/3 & 289/4 Vandalur Taluk, Chengalpattu District
2	Age of the building	30 Years
3	Purpose for Which building is certified for use	For Conducting School Classes
4	The license period for which the building will be structurally sound	From 27.12.2023 to 26.12.2026 (For Three years only)
5	No of persons to be accommodated	500
6	Remarks	
	(a)	No structures with inflammable roof must be allowed within the premises.
	(b)	If repairs and renovations are not done once in 6 months, this certificate will automatically be cancelled. Avoid stagnation of water in open terrace.
	(c)	This certificate covers the above mentioned buildings only and does not include any other structure or buildings within the premises for other purposes.
	(d)	This certificate does not include the eventualities cause by natural calamities, like high gale, earthquake, heavy rain, cyclone, storm, lightening, floods, fire, etc.
	(e)	If this certificate is tampered with illegally/unauthorized without the knowledge, permission and signature of the undersigned, this certificate will automatically be getting cancelled.
	(f)	This certificate is not conclude to any title dispute in respect of the property/building.
	(g)	The owner is instructed to check the roof materials, columns etc., now and the and if any material is damaged the same shall be replaced immediately, if not this certificate will automatically be getting open terrace, staircase and corridor must be barricaded.
	(h)	If additions or alterations shall be made without the prior permission and signature of the undersigned this certificate will automatically be getting cancelled.
	(i)	This certificate has been issued only on physical inspection of the premises.

SIGNATURE OF THE OWNER OF THE BUILDING


Correspondent
CRESCENT SCHOOL
Vandalur, Chennai-600 048.

PANEL AND STRUCTURAL ENGINEER


Dr. R. S. MURALITHARAN B.E., M.E (Struc), Ph.D
Registered Structural Engineer Grade-1 (SE)
CMDA Reg. No. SE/GR-1/19/12/233
DTCP Reg. No. CGLRGTN/SE/G-1/2020/02/004
District Panel Engineer Class-1A
Structural Engineer Consultant
No: 7A/25, Muthusamy Street, Perungalathur, Chennai-63.
☎ : 9489358800 ✉ : rsmurali06@gmail.com

FORM - C

Form of Certificate of Structural Soundness under sub-section (4) of section 4 of the Tamil Nadu Public Building (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.


I certify that the building mentioned in the statement and furnished below the silent technical features was inspected:

1		<i>Foundation</i>	Isolated Footing
	(a)	<i>Depth below ground level</i>	1.5 m below G.L
	(b)	<i>Nature of soil set out in the foundation level</i>	Murram
	(c)	<i>Pressure at foundation</i>	200kN /sq.m
	(d)	<i>Probable safe bearing capacity of soil at the foundation</i>	200kN /sq.m
2		<i>Super structure</i>	RCC framed structure
	(a)	<i>Maximum stress in the most critical masonry and concrete</i>	Panel wall in CM 1:5
	(b)	<i>Nature of masonry and concrete and permissible stress</i>	Masonry 3.5 kg /Sq.cm

The structural soundness of the building has been verified by me with referred to IS loading standards IS:875 (latest version) and other relevant Indian Standard code of practice and I declare that the building will be structurally sound to be used for the purpose noted in the statement. A license may be generated for the period from **27.12.2023 to 26.12.2026**.

Place: Chennai

Dated: Dec 2023



PANEL AND STRUCTURAL ENGINEER

Dr.R.S.MURALITHARAN B.E.,M.E.(Struct. Engrg.)
Registered Structural Engineer Grade-1 (SE)
CMDA Reg. No. SE/GR-1/19/12/233
DTCP Reg. No. CGLRGTN/SE/Gr-1/2020/02/004
District Panel Engineer Class-1A
Structural Engineer Consultant
No: 7A/25, Muthusamy Street, Perungalathur, Chennai-63.
☎: 9489358800 ✉: rsmurali06@gmail.com